

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1597:112 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: TEPG-US, 91 Technology Drive, Westminster, MA 01441-0001
Contact: Paul Mattern (978) 731-8542 FAX (978) 731-8881

DESIGN: Models 430657 and 431193 Releasing Device Peripheral with Model 430659 enclosure (for 430657 only). *Models T301-9101, -9102, -9106, and -9107 Abort Switches. *Models T301-9103 and -9104 Maintenance Switch with Lamp and Models 431196 and *T301-0051 Abort Supervision Module. The peripheral connects to both the IDNet SLC and a NAC output on the T310-9301 Series control unit (CSFM Listing No. 7170-1597:116) or a T310-9201 or T310-9211 (CSFM Listing No. 7300-1597:117) NAC expander. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-31 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as releasing device peripheral for use with listee's separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details

XLf: 7300-0026:313

*Rev 04-09-04



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

APRIL 9, 2004

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager